

# Certificate of Compliance

**Certificate:** 1898848 (Formerly 219738)

**Master Contract:** 237586

**Project:** 1898848

**Date Issued:** May 4, 2007

**Issued to:** Dwyer Instruments, Inc.  
102 Indiana Hwy 212  
Michigan City, IN 46361  
USA

**Attention:** Mr. Robert Thompson

*The products listed below are eligible to bear the CSA Mark shown  
with adjacent indicators 'C' and 'US'*



**Issued by:** Jeannette Keller

**Authorized by:**   
Peter Schimmoeller Manager  
of Certification Services

## PRODUCTS

**CLASS – 2258-02 - PROCESS CONTROL EQUIPMENT – For Hazardous Locations**  
**CLASS – 2258-82 - PROCESS CONTROL EQUIPMENT – For Hazardous Locations –  
Certified to US Standards**

**Class I; Division 2; Groups A, B, C, D; Class II, Division 2; Groups F, G; Class III**

- Model PMT rated 18-28 Vdc, 4-20 mA, -25 to 70 °C, T4, Process Temperature 120 °C max., Type 4X

**NOTE:** The temperature code is based upon the process temperature...and may be T5 for process temperature not exceeding 100 °C.

**Certificate:** 1898848

**Project:** 1898848



**Master Contract:** 237586

**Date Issued:** May 4, 2007

**APPLICABLE REQUIREMENTS**

CSA C22.2 No. 142-M1987 – Process Control Equipment

CSA C22.2 No. 213-M1987 – Nonincendive Equipment

UL 916:1998 – Energy Management Equipment

UL1604:1995 – Nonincendive Equipment

**MARKINGS**

- CSA Monogram with adjacent “C/US” indicators;
- Manufacturer’s Name or Report No.
- Supply rating
- Model or catalogue designation;
- Date code, serial number, or equivalent;
- Hazardous location designation, (Class I, Division 2, Groups A, B, C, D)
- Temperature Code



CSA INTERNATIONAL

## Supplement to Certificate of Compliance

Certificate: 1898848

Master Contract: 237586

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

Project	Date	Description
1898848	May 4, 2007	Original Certification. Model comparison for Filter Sense. Report No. 219738-1871249.

Filter Sense	Dwyer Instruments, Inc.
EM 30T-1P	PMT